

# Certificate of Conformity

Certificate Number: CN-PV-230707

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

**Applicant:** Hangzhou Livoltek power Co., Ltd.  
1418-35 Moganshan Road, Shangcheng Industrial Zone, Hangzhou, Zhejiang Province, China

**Product:** ON-GRID SOLAR INVERTER

**Ratings & Principle Characteristics:** See appendix of Certificate of Conformity

**Model:** GT3-17KL-D, GT3-20KL-T, GT3-25KL-T, GT3-30KL-Q

**Brand Name<s>:** **LIVOLTEK**

**Product Complies with:** IEC 61727:2004  
IEC 62116:2014

**Certificate Issuing Office Name & Address:** Intertek Testing Services Ltd. Shanghai  
West Area, 2<sup>nd</sup> Floor, No. 707, Zhangyang Road  
China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China  
Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012

**Test Report No.<s>:** 231200599SHA-001

Additional information in Appendix.

Signature



**Certification Manager: Qiao Qiao**  
**Date: 27 December 2023**



PRD N° 306B

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230707

### Ratings & Principal Characteristics:

Specifications table				
Model	GT3-17KL-D	GT3-20KL-T	GT3-25KL-T	GT3-30KL-Q
<b>PV input</b>				
P <sub>pv</sub> Max(W)	25500	30000	37500	45000
V <sub>max</sub> PV (Vdc) (absolute Max.)	750	750	750	750
I <sub>sc</sub> PV (absolute Max.) (A)	48x2	48x3	48x3	48x4
Number MPP trackers	2	3	3	4
Number input strings	2/3	2/2/2	2/2/3	2/2/2/2
Max. PV input current (A)	38x2	38x3	40x3	38x4
MPPT voltage range (Vdc)	200-700	200-700	200-700	200-700
Vdc range @ full power (Vdc)	310-600	320-600	300-600	300-600
<b>AC Grid (output)</b>				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	42.7	50.2	62.7	75.2
Max. cont. output current (A)	48	60	80	96
Normal Power (W)	17000	20000	25000	30000
Rated Apparent Power (VA)	17000	20000	25000	30000
Max. cont. Power (W)	17000	20000	25000	30000
Max. cont. Apparent Power (VA)	17000	20000	25000	30000
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>Others</b>				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.